

Envelope Sealing Performed For:

Sunlight Solar, Paul Isreal
150 NE Hawthorne Ave
Bend, OR 97701

AEROBARRIER CASE ID: 8083

HARDWARE: AeroBarrier

DATE:
11/3/2020

BUILDING TYPE:
Single Family Detached

Envelope Sealing Results:

BEFORE SERVICE

6495.1 CFM of Leakage, equivalent to a
600.8 Square Inch Hole or
0.27 CFM₇₅ per Square Foot

(for your 15000 square-foot structure
with a surface area of 23932 square feet)


AFTER SERVICE

1171.7 CFM of Leakage, equivalent to a
108.4 Square Inch Hole or
0.05 CFM₇₅ per Square Foot

This corresponds to a
82.0% Reduction
in Envelope Leakage

NOTE: Envelope leakage and air-change results are
calculated at a standard pressure of 75 Pa.

Envelope Sealing Progress:



Envelope Sealing Performed By:



NorthWest AeroBarrier
PO Box 5488
Bend, OR 97708
Phone: 541.728.3634